


▼ Solution:

Surge level:

IEC61000-4-5

1.2/50us & 8/20us

DM 2KV /1KA



Specification.....

Part Number	Vbr	Ir	Vrwm	Ipp	Vc	Package
TVS	V	uA	V	A	V	
SMDJ58CA	64.4- 74.1	5	58	32.0	93.6	SMC

Statement: These solution is only for reference, The final solution will be based on the actual test results, HUAAN LIMITED will have the right of final explanation.

sales@huaandz.com

abc0734@126.com